

**Government of Andhra Pradesh**  
**A.P. State Disaster Response and Fire Services Department**  
**Fire No Objection Certificate for Occupancy**

**File No: 26207/KKN/MSB/2025**

**Date: 01/04/2025**

Sir/Madam,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Issue of Fire No Objection Certificate for Occupancy to the existing building of **(ADARSH COLLEGE OF ENGINEERING) BURRA ANURADHA, Door No: 15-186, Chebrolu Village, Gollaprolu Mandal, Kakinada District., 533449** - Regarding.

Ref: Online Application Dt. 23-04-2025

\*\*\*\*\*

Having satisfied with the reasonable fire safety measures that you have affirmed to have undertaken in your School/College buildings. I hereby grant Occupancy Fire NOC for a period of One year.

1. Ensured two exits/two staircases for orderly evacuation of teachers, students and staff in case of any fire incident or emergency.
2. Conduct Mock Drill @ twice a year with participation of teachers, students and preferably in presence some of the parents. And take signatures of staff, teachers, parents, student leaders affirming their familiarity with the equipment and its functioning.
3. **Ensured Electrical Safety by observing the following Precautions:**
  - a. Installation of Miniature Circuit Breakers (MCBs) in all floors.
  - b. No Overloading of power sockets in any Educational Building.
  - c. 10 years old wiring to be changed, especially where high power consuming appliances such as Air conditioners, Electrical/Mechanical/Computer labs, High-tech labs, etc., are used.
  - d. Grounding/Earthing shall be done.
  - e. Lightning conductors may be provided for high-rise buildings exceeding 5 floors.
  - f. No High Tension Lines should run inside or in close proximity (< 6 meters) to any Educational institution buildings.
  - g. No charging for EV vehicles @ cellars of School/College buildings.

Let the above be tested and certified by any electrical Engineer without regard to any Jurisdiction under employment of Government of Andhra Pradesh once a year.

4. As the ensuring safety is a continuous learning process, we will advise from time to time, practical , modern , reliable but not too hard or that require major modifications to your building structure. And you shall undertake to observe these precautions to enhance fire safety.
5. Therefore, this building meets the **“reasonable fire safety criteria”** as envisaged in NBC and hence the Fire No Objection Certificate for Occupancy is issued.
6. As a Policy, no retrospective application of rules shall be made for building as long as they comply with that NOC requirements till the life of the building.
7. Any clarifications, you are welcome to meet the DG, Fire Services (9441236448) without appointment in his office as ensuring fire safety with better and affordable technology is a continuous learning and collaborative endeavour.(for school fire safety mock drill, visit [https://www.youtube.com/watch?v=OW-oyYEAT\\_4](https://www.youtube.com/watch?v=OW-oyYEAT_4))

Your Sincerely,

Director General

State Disaster Response & Fire Services  
Andhra Pradesh, Vijayawada.

To

The Management of ADARSH COLLEGE OF ENGINEERING, BURRA ANURADHA,  
Door No: 15-186, Chebrolu Village, Gollaprolu Mandal, Kakinada District., 533449

Copy to the District Educational Officer, Concerned.

Copy to the Secretary Board of Intermediate Education, Andhra Pradesh, Vijayawada